

Introduction

This report is intended to provide you with important information about your tap water and the efforts made by the water system to meet all U.S.E.P.A. and State drinking Water health standards. The City vigilantly safeguards its water supply and this report summarizes the quality of water that we provided last year, including details about where the water comes from, what it contains and how it compares to standards set by regulatory agencies. We are committed to providing you with this information about the water you are receiving. If you have any questions about this report or concerns about your water system, please contact Jerome Kopeck at the Sesser Water Dept at (618) 625-3611. Board meetings are held the Second Thursday of each month at 6:30 pm at the Community Bld located at 110 North Walnut St. in Sesser IL.

Water Source Assessment

Water is Purchased Surface water from the Rend lake Intercity water system. The source water assessment for our supply has been completed by the Illinois E.P.A. The Illinois E.P.A considers all surface water sources susceptible to potential pollution problems. Hence the reason for mandatory treatment of all public water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation. Filtration and disinfection. Primary sources of pollution in Illinois lakes can include agricultural runoff, land disposal (septic systems) and shoreline erosion. For your own copy of this report you may obtain a copy at City hall or access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Health Issues

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/Aids or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. US E.P.A. / C.D.C. guide lines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the USEPA'S Safe Drinking Water Hotline at 1-800-426-4791.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health affects can be obtained by calling the USEPA'S Safe Drinking Water Hotline at 1-800-426-4791.

In order to insure that tap water is safe to drink, USEPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminant Source

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it can dissolve naturally occurring minerals and radio active material, and can pick-up substances resulting from the presence of animals or from human activity. Possible contaminants consist of;

- Microbial Contaminants such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic Contaminants such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges oil and gas production, mining or farming.
- Pesticides & Herbicides which may come from a variety of sources such as Agricultural, urban storm water runoff.
- Organic Chemical Contaminant including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff and septic system's.
- Radioactive Contaminants which maybe naturally occurring or be the result of oil and gas production and mining activities.
- Lead: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The drinking water supplier is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in your home plumbing. You share the responsibility for protecting yourself and your family from the lead in your home plumbing by identifying and removing lead plumbing from your home. Before drinking tap water, flush your pipes for several minutes by running the tap, taking showers, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water, call the water office at 618-625-3611. Information on lead in drinking water, testing availability and steps you can take to minimize exposure to lead is available at <http://www.epa.gov/safewater/lead>.

Sesser Water Department.

Annual Drinking Water Quality Report
City of Sesser Illinois
II0550450

Annual Water Quality Report
For the period of January 1 to December 31, 2024

This report is intended to provide you with important information about you drinking water and the effects made by the City of Sesser water system to provide safe drinking water. The source of drinking water used by the City is purchased from the Rend Lake Conservancy District.

Regulated Contaminants Detected in 2024 (collected in 2024 unless noted)

City of Sesser Water Department

Lead and Copper Definitions: Action Level (AL); the concentration of contaminant which, if exceeded, triggers treatment or other requirements within a water system. Action Level Goal (ALG); the concentration of a contaminant in drinking water below which there is no known or expected risk to health

Lead Range: 0 to 0 ppb Copper Range: 0 to .14 ppm

OUR COMMUNITY WATER SUPPLY HAS DEVELOPED A SERVICE LINE MATERIAL INVENTORY, TO OBTAIN A COPY OF THIS SYSTEM'S SERVICE LINE INVENTORY AND/OR THE LEAD TAP SAMPLING DATA, PLEASE CONTACT THE SESSER WATER DEPARTMENT AT 618-625-3611.

Lead MCLG	Lead Action Level (AL)	Lead 90 th Percentile	# sites Over Lead AL	Copper MCLG	Copper Action Level (AL)	Copper 90 th Percentile	# Sites Over Copper AL	Likely Source of contamination
0 ppb Violations none	10 ppb	0	0	1.3 ppm Violations none	1.3 ppm	0.0513	0	Corrosion of household plumbing system & Erosion of natural deposits.

Water quality Test Results

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Na: Not applicable

Maximum Contaminant Level (MCL); the highest level of a contaminant that is allowed in drinking water. MCL's are set as choice to Contaminant Level Goal as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no longer know or expectant health risks. MCLG's allow for a margin of safety.

Mg/l or ppm: milligrams per liter or parts per million- or one ounce in 7,350 gallons of water

ug/l or ppb: micrograms per liter or parts per billions- or one ounce in 7,350,000 gallons of water

mrem: millirems per year (a measure of radiation absorbed by the body)

pCi/L: Picocuries per liter- a measure of radioactivity

Avg: Regulatory compliance which some MCLs are based on running annual average of monthly samples

Maximum Residual Disinfectant Level (MRDL): the highest level of disinfectant allowed in drinking water

Maximum Residual Disinfectant Level (MRDLG): the level of disinfectant in drinking water below which there is no known or expectant health risks. MRDLG's allow margin of safety.

TT or Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

Level 1 Assessment: A level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. Coli MCL violation has occurred and /or why total coliform bacteria have been found in our water system on multiple occasions.

State Regulated Disinfectants & Disinfection By Products

Regulated Contaminants Collected in 2024	Highest Level	Range of Levels Detected	Unit of Measurement	MCLG	MCL	Violation	Likely source of contamination
Chloramines	2.7	2.5 - 3	ppm	Mrdlg = 4	Mrdlg= 4	No	Water additive used to control microbes
Total Haloacetic Acids (HAA5)	22	12 - 37.6	ppb	No goal for the total	60	No	By-product of drinking water chlorination
TTHM (Total Trihalomethanes)	43	25 - 68	ppb	No goal for the total	80	No	By-product of drinking water chlorination

Not all sample results may have been used for calculating the highest level detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.

REND LAKE RESULTS 2024

State Regulated Inorganic Contaminant Collected in 2024	Highest Level	Range of Levels	Unit of Measurement	MCLG	MCL	Violation	Likely source of Contaminant.
Arsenic	2	1.93-1.93	ppb	0	10	No	Erosion of natural deposits; Runoff from orchards. Runoff from glass and electronics production wastes.
Barium	0.0116	0.0116-0.0116	ppm	2	2	No	Discharge of drilling waste, discharge for metal refineries, Erosion of natural deposits
Fluoride	0.7	0.66-0.66	ppm	4	4	No	Erosion of natural deposits, water addition for strong teeth. Discharge from fertilizer and aluminum factories.
Sodium	23	22.9 -22.9	ppm	n/a	n/a	No	Erosion of naturally occurring deposits, used in water softener regeneration.

Radioactive Contaminants Collected 01/22/2022	0.86	0.86-0.86	pCi/L	0	5	No	Erosion of Naturally occurring deposits
Combined Radium 226/228							
Gross alpha excluding radon and uranium	0.12	0.12-0.12	pCi/l	0	15	No	Erosion of Naturally occurring deposits

Turbidity- Regulated at the Water Treatment Plant- Information Statement: Turbidity is a measurement of the cloudiness of the particles. We monitor it because it is a good indicator of water quality and effectiveness of our filtration and disinfectants

Limit (Treatment Technique)	Lowest Monthly % meeting limit	Violation	Source
1 NTU	100%	No	Soil runoff
0.3 NTU	Highest single measurement 0.44 NTU	No	

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirement set, unless a TOC Violation is noted in the violation section.